

189


PRÉCIS OF
ECONOMIC ASSESSMENT OF BACKFITTING
POWER PLANTS WITH
CLOSED-CYCLE COOLING SYSTEMS

by

A. R. Giaquinta, T. E. Croley II, V. C. Patel,
J. G. Melville, M. S. Cheng, and A. S. Uzuner

Prepared for U.S. Environmental Protection Agency
Contract No. 68-03-0430
ROAP No. 21AZU-019
Program Element No. 1BB392

PLEASE DO NOT REMOVE



Published by: EPA Report No. EPA-600/2-76-050
IIHR Report No. 189

Iowa Institute of Hydraulic Research
The University of Iowa
Iowa City, Iowa

PRÉCIS OF
ECONOMIC ASSESSMENT OF BACKFITTING
POWER PLANTS WITH
CLOSED-CYCLE COOLING SYSTEMS *

by

A. R. Giaquinta, T. E. Croley II, V. C. Patel,
J. G. Melville, M. S. Cheng, and A. S. Uzuner

Prepared for U.S. Environmental Protection Agency
Contract No. 68-03-0430
ROAP No. 21AZU-019
Program Element No. 1BB392

*Includes the title page, abstract, table of contents, list of figures, list of tables, acknowledgements, and the introductory sections of a report prepared by the Iowa Institute of Hydraulic Research for the U.S. Environmental Protection Agency. The complete report (371 pages) is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

Published by: EPA Report No. EPA-600/2-76-050
IIHR Report No. 189

Iowa Institute of Hydraulic Research
The University of Iowa
Iowa City, Iowa

ABSTRACT

This report describes a detailed methodology for the assessment of the economic consequences of backfitting electric power plants, currently operating on open-cycle or once-through cooling systems, with conventional closed-cycle cooling systems. In particular, four different types of closed-cycle cooling systems have been investigated: 1) mechanical-draft crossflow wet cooling towers, 2) natural-draft crossflow wet cooling towers, 3) cooling ponds, and 4) spray canals. Representative thermodynamic models have been used to reproduce the operating characteristics of different types of turbines, condensers, and cooling systems in order to estimate the operational penalties associated with backfitting. Available capital and operating cost information has been compiled and used, in conjunction with the levelized annual cost method of accounting, to evaluate the total differential cost of power production resulting from the backfit.

Since the operating consequences, such as replacement capacity, energy losses, excess fuel consumption, and water requirements depend upon the size and type of existing turbines, fluctuations in power demand, size of the cooling system, and variations in the meteorological conditions at the site, detailed analyses of backfitting are best performed with the aid of a digital computer. Suitable computer programs have therefore been developed and presented. To facilitate rapid assessment of differential costs, however, a large number of representative calculations have been performed and are presented graphically. In particular, the results for three different types of conventional turbines and four different geographical sites have been obtained for

a range of cooling-system sizes, and they are depicted in suitable plots. Once the various unit costs of replacement capacity, energy loss, fuel, and water are known, these results can be used to evaluate the cost to be assessed against backfitting. Representative values of the unit costs are included in the report.

This report was submitted in fulfillment of Contract No. 68-03-0430, by the Iowa Institute of Hydraulic Research, The University of Iowa, Iowa City, Iowa, under the sponsorship of the Environmental Protection Agency. Work was completed as of January 31, 1975.

CONTENTS

<u>Section</u>	<u>Page</u>
I CONCLUSIONS	1
II RECOMMENDATIONS	6
III INTRODUCTION	8
IV GENERAL CONSIDERATIONS AND ASSUMPTIONS	12
A. Turbine characteristics	15
B. Geographical location and meteorological conditions	32
C. Economic considerations	39
D. Treatment of a variable loading pattern	49
V MECHANICAL-DRAFT WET COOLING TOWERS	51
A. Capital cost of towers (C_{CS}) and auxiliary equipment	54
B. Reference length of cooling towers, L^*	67
C. Operation of a tower of given size (L, H)	71
D. Parametric studies	74
E. Operating costs with cooling towers	85
F. Procedure for the economic evaluation of backfitting	104
G. The computer program	108
H. A hypothetical test case	111
J. Example of a variable loading pattern	116
VI NATURAL-DRAFT WET COOLING TOWERS	120
A. Operation models for natural-draft, crossflow, wet cooling towers	124
B. Capital cost of towers and auxiliary equipment	128

CONTENTS (continued)

<u>Section</u>	<u>Page</u>
C. Reference size of cooling towers, S*	133
D. Operation of a tower of given size (S, H)	136
E. Parametric studies	136
F. Procedure for the economic evaluation of backfitting	143
G. The computer program	184
H. A hypothetical test case	186
VII COOLING PONDS	192
A. Operation model for the fully-mixed pond	193
B. Capital costs of cooling ponds	197
C. Reference area of cooling pond, A*	199
D. Parametric studies	199
E. Procedure for the economic evaluation of backfitting	222
F. The computer program	223
G. A hypothetical test case	224
VIII SPRAY CANALS AND PONDS	229
A. Operation models of spray cooling	231
B. Capital costs of spray canals	239
C. Reference size of spray canals, N*	241
D. Parametric studies	242
E. Procedure for the economic evaluation of backfitting	265
F. The computer program	266
G. A hypothetical test case	267
IX REFERENCES	273
X GLOSSARY OF SYMBOLS	278
XI APPENDICES	284

FIGURES

<u>Number</u>	<u>Title</u>	<u>Page</u>
1	Typical turbine heat rate correction curves	16
2	Typical turbine heat rejection rate characteristics	19
3	Typical variation of plant efficiency with turbine back pressure	21
4	Heat rate characteristics of turbine A	27
5	Heat rate characteristics of turbine B	28
6	Heat rate characteristics of turbine C	29
7	Variation of the fixed charge rate with remaining life of plant or unit	47
8	Overall view of typical mechanical-draft tower	53
9	Mechanical-draft crossflow tower	53
10	Typical rating factor charts for mechanical-draft crossflow towers	55
11	Relation between tower units and physical dimensions of the tower	58
12	Range, approach and water flow rate as functions of tower size	
	(a) $T_{wb_d} = 60^{\circ}\text{F} (15.56^{\circ}\text{C})$	60
	(b) $T_{wb_d} = 70^{\circ}\text{F} (21.11^{\circ}\text{C})$	61
	(c) $T_{wb_d} = 80^{\circ}\text{F} (26.67^{\circ}\text{C})$	62
13	Capital cost of pump and pipe system	63
14	Required surface area of new condensers	64
15	Construction for the definition of reference tower length, L^*	69

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
16	Reference length of towers	70
17	Variation of capacity loss with tower size and plant capacity	75
18	Variation of energy loss with tower size and plant capacity	76
19	Variation of excess fuel consumption with tower size and plant capacity	77
20	Variation of evaporation with tower size and plant capacity	78
21	Normalized capacity loss	81
22	Normalized energy loss	82
23	Normalized excess fuel consumption	83
24	Normalized evaporation	84
25	Normalized capacity loss	
	(a) Chicago	86
	(b) Los Angeles	87
	(c) Miami	88
	(d) St. Louis	89
26	Normalized energy loss	
	(a) Chicago	90
	(b) Los Angeles	91
	(c) Miami	92
	(d) St. Louis	93
27	Normalized excess fuel consumption	
	(a) Chicago	94
	(b) Los Angeles	95
	(c) Miami	96
	(d) St. Louis	97
28	Normalized evaporation	
	(a) Chicago	98

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
	(b) Los Angeles	99
	(c) Miami	100
	(d) St. Louis	101
29	Hyperbolic natural-draft crossflow, wet cooling tower	122
30	Pile characteristics curve and air flow rate calculations	125
31	Typical cost-performance curves for budget estimates for the natural-draft crossflow cooling tower (1970 dollars)	129
32	Capital cost estimates for the natural-draft crossflow, wet cooling tower	131
33	Determination of reference shell height	135
34	Normalized capacity loss	137
35	Normalized energy loss	138
36	Normalized excess fuel consumption	139
37	Normalized evaporation	140
38	Variation of normalized capacity loss with shell height and plant capacity, 36% turbine efficiency	144
39	Variation of normalized energy loss with shell height and plant capacity, 36% turbine efficiency	145
40	Variation of normalized excess fuel consumption with shell height and plant capacity, 36% turbine efficiency	146
41	Variation of normalized evaporation with shell height and plant capacity, 36% turbine efficiency	147
42	Variation of normalized capacity loss with shell height and plant capacity, 28% turbine efficiency	148
43	Variation of normalized energy loss with shell height and plant capacity, 28% turbine efficiency	149

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
44	Variation of normalized excess fuel consumption with shell height and plant capacity, 28% turbine efficiency	150
45	Variation of normalized evaporation with shell height and plant capacity, 28% turbine efficiency	151
46	Normalized capacity loss, 36% turbine efficiency	
	(a) Chicago	152
	(b) Los Angeles	153
	(c) Miami	154
	(d) St. Louis	155
47	Normalized energy loss, 36% turbine efficiency	
	(a) Chicago	156
	(b) Los Angeles	157
	(c) Miami	158
	(d) St. Louis	159
48	Normalized excess fuel consumption, 36% turbine efficiency	
	(a) Chicago	160
	(b) Los Angeles	161
	(c) Miami	162
	(d) St. Louis	163
49	Normalized evaporation, 36% turbine efficiency	
	(a) Chicago	164
	(b) Los Angeles	165
	(c) Miami	166
	(d) St. Louis	167
50	Normalized capacity loss, 28% turbine efficiency	
	(a) Chicago	168
	(b) Los Angeles	169
	(c) Miami	170

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
	(d) St. Louis	171
51	Normalized energy loss, 28% turbine efficiency	
	(a) Chicago	172
	(b) Los Angeles	173
	(c) Miami	174
	(d) St. Louis	175
52	Normalized excess fuel consumption, 28% turbine efficiency	
	(a) Chicago	176
	(b) Los Angeles	177
	(c) Miami	178
	(d) St. Louis	179
53	Normalized evaporation, 28% turbine efficiency	
	(a) Chicago	180
	(b) Los Angeles	181
	(c) Miami	182
	(d) St. Louis	183
54	Reference area of cooling ponds	200
55	Normalized capacity loss	202
56	Normalized energy loss	203
57	Normalized excess fuel consumption	204
58	Normalized evaporation	205
59	Normalized capacity loss	
	(a) Chicago	206
	(b) Los Angeles	207
	(c) Miami	208
	(d) St. Louis	209
60	Normalized energy loss	
	(a) Chicago	210
	(b) Los Angeles	211

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
	(c) Miami	212
	(d) St. Louis	213
61	Normalized excess fuel consumption	
	(a) Chicago	214
	(b) Los Angeles	215
	(c) Miami	216
	(d) St. Louis	217
62	Normalized evaporation	
	(a) Chicago	218
	(b) Los Angeles	219
	(c) Miami	220
	(d) St. Louis	221
63	Reference size of spray canals	243
64	Normalized capacity loss	245
65	Normalized energy loss	246
66	Normalized excess fuel consumption	247
67	Normalized evaporation	248
68	Normalized capacity loss	
	(a) Chicago	249
	(b) Los Angeles	250
	(c) Miami	251
	(d) St. Louis	252
69	Normalized energy loss	
	(a) Chicago	253
	(b) Los Angeles	254
	(c) Miami	255
	(d) St. Louis	256
70	Normalized excess fuel consumption	
	(a) Chicago	257
	(b) Los Angeles	258

FIGURES (continued)

<u>Number</u>	<u>Title</u>	<u>Page</u>
	(c) Miami	259
	(d) St. Louis	260
71	Normalized evaporation	
	(a) Chicago	261
	(b) Los Angeles	262
	(c) Miami	263
	(d) St. Louis	264

TABLES

<u>Table</u>	<u>Page</u>
1 Reference conditions for turbines A, B and C for example calculations	31
2 Annual summary of weather data at Miami	34
3 Frequency of occurrence of T_{wb} , T_{db} at Miami	37
4 Temperatures equalled or exceeded less than 10 hrs/yr	38
5 "Design" temperatures for cooling towers	38
6 Capital cost of replacement capacity and fuel (1980 estimates)	43
7 Variable loading pattern for mechanical-draft wet cooling tower example	117
8 Comparison of selected results from the mechanical- draft wet cooling tower examples for different loading patterns	118

ACKNOWLEDGEMENTS

This study was sponsored by the Environmental Protection Agency under Contract No. 68-03-0430. Special acknowledgement is due to Mr. James P. Chasse, the EPA Project Officer, for making constructive suggestions and for providing useful information and literature, not readily accessible elsewhere, at several stages of the study. Acknowledgement is also due to the many individuals and companies who responded to our plea for realistic design, performance and cost data for various types of cooling systems. In particular, we are grateful to the staff of the Marley Company (Mission, Kansas), for their assistance with the analysis of cooling towers, and to the Ashbrook Corporation (Houston, Texas), Cherne Industrial, Inc. (Edina, Minnesota), and Richards of Rockford, Inc. (Rockford, Illinois) for the information which they supplied related to spray cooling.

SECTION I
CONCLUSIONS

The general methodology for the economic evaluation of backfitting power plants with closed-cycle cooling systems has been presented. The following major conclusions can be drawn from the study.

1. The computer programs developed here can be used to assess the total differential cost of backfitting power plants with any of the following closed-cycle systems:

- Mechanical-draft crossflow wet cooling towers,
- Natural-draft crossflow wet cooling towers,
- Cooling ponds, and
- Spray canals.

The programs accept as input data turbine size and characteristics, size of cooling system, fluctuations in power demand, variations in site meteorological conditions, and economic parameters. The thermodynamic and performance models used to evaluate the operating consequences such as capacity and energy losses, excess fuel consumption and water requirements are representative of those in current use. The overall accuracy of the economic predictions therefore depends largely on accurate projection of the capital cost of the cooling system and on the unit costs associated with capacity replacement, make-up energy and fuel. While an effort has been made to incorporate the most recent estimates for capital costs of cooling systems, it is also recognized that these costs vary over a wide margin, particularly in the cases of cooling ponds and spray canals, due to unforeseen problems associated

with construction at particular sites.

2. The overall complexity of the backfit analysis is such that it does not allow the use of simplified models and construction of simple nomographs for general use. Nevertheless, it has been possible to obtain a comprehensive set of results from selected model applications which will enable a rapid evaluation of the total cost of backfitting when some of the basic characteristics of the power plant, the cooling system, and the site are known. A considerable amount of generality has been achieved by (a) assuming that the power demand remains constant at the full-throttle value of the turbine; (b) presenting in a graphical form only the basic quantities such as capacity loss, energy loss, excess fuel consumption and water evaporation as functions of cooling-system size in a convenient format, so that these quantities can be evaluated for any given nameplate capacity of the turbine and size of the cooling system; (c) estimating the capital cost of the cooling system in terms of its physical size and not in terms of thermodynamic properties of the system; and (d) performing the calculations for three different types of turbines and for four climatically different sites. The presentation of the results in this form is particularly useful since the influence of using different values of the economic parameters, such as capital cost of cooling system, unit costs of replacement capacity and energy, etc., can be investigated with ease. The use of these results has been illustrated by means of a hypothetical example for each of the four closed-cycle cooling systems.
3. The actual performance of the affected power plant or unit in open-cycle operation can be investigated by modifying the basic procedures to include the variations in the water-body temperature. Such an alteration was not, however, considered in the present study since it would have resulted in a loss of generality which was considered essential for the presentation of the results in

simple graphical form.

4. The present study indicates that the total cost of backfitting, in mills/kW-hr of energy delivered, depends mainly on the capital cost of the cooling system, the capital cost associated with the replacement of lost capacity, the operating costs of peaking plants built to replace the energy losses, and the excess fuel consumption of the affected units due to higher back-pressure operation resulting from the backfit. Under the assumption of full-throttle power demand, however, the excess fuel consumption is much smaller than would actually result from a variable power demand, but there is a corresponding increase in the energy losses. Comparison between the detailed calculations using the computer programs with realistic power demand variations and those performed using the graphical results with full-throttle power suggest that the total costs calculated by the two methods may differ only by a few percent. This small difference gives added confidence in the use of the results presented graphically.

5. The sensitivity of the total cost of backfitting to the factors listed above suggests that great care must be taken in estimating the following for each application:

- Capital cost of the cooling system,
- Unit cost of replacement capacity,
- Unit cost of replacement energy,
- Unit cost of fuel, and
- Fixed charge rate.

As indicated earlier, the first of these quantities can be found readily from the data presented in this report, but an on-going check must be maintained in order to ascertain the impact of inflation within the industry. Needless to say, the most reliable and up-to-date information can best be obtained directly from the manufacturers and construction engineers.

A considerable amount of variation in these costs can be expected from site to site, but for cooling towers the estimates presented here appear to be reliable within about 15 percent for applications up to 1980. The remaining factors listed above depend upon the particular utility situation. However, if capacity and energy losses are to be made up by means of gas-turbine peaking units, the unit costs will be of the order of \$100/kW for capacity replacement and 10 mills/kW-hr for energy replacement based upon 1975 estimates.

6. In the hypothetical examples analyzed in detail in the text, where the power plant characteristics as well as the site meteorological conditions were approximately the same for all four closed-cycle cooling systems, the total excess unit costs of backfitting (in mills/kW-hr) were found to be

Mechanical-draft crossflow wet cooling towers:	0.582
Natural-draft crossflow wet cooling towers	: 0.916
Cooling ponds	: 0.666
Spray canals	: 0.694

These costs can not, of course, be compared on an absolute scale since the size of each cooling system was chosen arbitrarily, and no attempt was made to verify an "optimum" size. Nevertheless, since each size is realistic and since the same values of the unit costs of replacement capacity, replacement energy, fuel, water, and fixed charge rate have been used, the total costs listed above give a good general indication for each type of cooling system.

7. The computer programs as well as the graphical results of the present study can be used to make an independent assessment of the cost of backfitting a given power plant or unit at a known site with a range of sizes of the four different types of closed-cycle cooling systems.

8. Finally, the assessment of backfitting costs can best be made for any particular situation by using the computer models given in the appendices. No interpolation error will be involved, and inclusion of the actual design power loading for the specific situation may be made (instead of the assumed "full-throttle" design loading implicit in the figures of this report). The programs are designed to accommodate a design loading composed of two power levels (one of which is the maximum) and can be easily extended to more.

SECTION II

RECOMMENDATIONS

Four major recommendations are made on the basis of the present study:

1. As far as possible, the computer programs presented in this report should be used to independently assess the economic consequences of backfitting power plants with closed-cycle cooling systems and to compare the estimated total costs with those evaluated by other methods. Rapid estimates of backfitting costs can also be made by using the representative set of graphical results, which will, however, involve a certain amount of approximation.
2. The utilization of the computer programs allows the economic analysis of backfitting to be based upon the actual design power loading instead of the full-throttle loading assumed in the graphical results. Design power loadings with more than two defined levels of power output can be analyzed with slight modifications of the program. The actual performance of the affected unit during open-cycle operation can also be modeled by incorporating expected variations in the water-body temperature in the program.
3. The validity of any economic analysis of cooling systems will depend upon the proper selection of individual cost factors and constraints. Among the more important site-specific considerations is the requirement for land and its availability. While the example problems for cooling towers in this report have land

requirements based on noise attenuation, other criteria such as construction area and plume recirculation may be more applicable.

4. An on-going survey should be maintained to determine the prevailing and expected costs of cooling systems, unit costs of replacement capacity, replacement energy, fuel, and water, as well as the fixed charge rate, so that the general methodology developed for this study can be updated periodically.

SECTION III

INTRODUCTION

Following the recent enactment of "environmental" legislation (The Federal Water Pollution Control Act Amendments of 1972), the Environmental Protection Agency has been charged with the task of developing guidelines and standards of performance for steam electric power plants. Originally, the EPA's proposed §304 guidelines and §306 standards [1,2,3,4] suggested that, except for the power plants receiving exemption under §316(a), all plants operating with open-cycle cooling systems should be backfitted with closed-cycle systems by the year 1983. However, these guidelines soon met with much opposition, and in ensuing adversary hearings, a set of revised guidelines were constructed [5]. In accordance with these new EPA guidelines, the thermal discharges are to be limited according to the following schedule [6:§423.13 l(1)-(6),m]:

A. There shall be no discharge of heat from the main condensers except

(1) "Heat may be discharged in blowdown from recirculated cooling water systems provided the temperature at which the blowdown is discharged does not exceed at any time the lowest temperature of recirculating cooling water prior to the addition of the make-up water.

(2) "Heat may be discharged in blowdown from recirculated cooling water systems which have been designed to discharge blowdown water at a temperature above the lowest temperature of recirculated cooling water prior to the addition of make-up water providing such recirculating cooling systems have been placed in operation or are under construction prior to the effective date of this regulation (July 1, 1981).

(3) "Heat may be discharged where the owner or operator of a unit otherwise subject to this limitation can demonstrate

that a cooling pond or cooling lake is used or is under construction as of the effective date of this regulation to cool recirculated cooling water before it is recirculated to the main condensers.

(4) "Heat may be discharged where the owner or operator of a unit otherwise subject to this limitation can demonstrate that sufficient land for the construction and operation of mechanical draft evaporative cooling towers is not available (after consideration of alternate land use assignments) on the premises or on adjoining property under the ownership or control of the owner or operator as of March 4, 1974, and that no alternate recirculating cooling system is practicable.

(5) "Heat may be discharged where the owner or operator of a unit otherwise subject to this limitation can demonstrate that the total dissolved solids concentration in blowdown exceeds 30,000 mg/l and land not owned or controlled by the owner or operator as of March 4, 1974, is located within 150 meters (500 feet) in the prevailing downwind direction of every practicable location for mechanical draft cooling towers and that no alternate recirculating cooling system is practicable.

(6) "Heat may be discharged where the owner or operator of a unit otherwise subject to this limitation can demonstrate to the regional administrator or State, if the State has NPDES permit issuing authority, that the plume which must necessarily emit from a cooling tower would cause a substantial hazard to commercial aviation and that no alternate recirculated cooling water system is practicable. In making such demonstration to the regional administrator or State the owner or operator of such unit must include a finding by the Federal Aviation Administration that the visible plume emitted from a well-operated cooling tower would in fact cause a substantial hazard to commercial aviation in the vicinity of a major commercial airport.

(m) "The limitation of paragraph (1) of this section shall become effective on July 1, 1981.

B. These new guidelines shall have both the exclusions implicit in the above paragraphs and the additional exclusions outlined here:

units on line before January 1, 1970, are excluded;
units of 500MW or less on line before January 1, 1974,
are excluded;
units of less than 25MW are excluded; and
units in a system of 150MW or less are excluded.

The above guidelines are to be effective July 1, 1981, as indicated in paragraph (m) above; however, there are provisions of deferral of compliance until July 1, 1983, if system reliability would be seriously

affected.

The present study is concerned with the development of a detailed methodology for the evaluation of the cost of backfitting a plant or unit currently operating on open-cycle with a closed-cycle cooling system. Four different closed-cycle systems are considered:

Mechanical-Draft Crossflow Wet Cooling Towers,
Natural-Draft Crossflow Wet Cooling Towers,
Cooling Ponds, and
Spray Canals.

It is recognized that a large number of conflicting factors enter into the estimation of the cost of backfitting. Since many of these are highly site-dependent, it is not possible to arrive at general conclusions applicable to all utility situations. However, the purpose here has been to develop a method which is flexible enough to take these factors into consideration so that when they are prescribed or determined the cost can be estimated.

The evaluation of the additional costs against the power generated is important to the utility since it provides a basis for determining the necessary rate increases. Of major concern in the backfitting operation is the fact that the capacity of the unit will be reduced by the amount of power consumed within the closed-cycle system and by penalties that may be incurred by requiring adjustments in the operating characteristics of the unit, the main factor being the increase in the turbine exhaust pressure. This lost capacity must be replaced either by adding new capacity at the same site or elsewhere, or by operating other units at higher levels.

The major factors to be considered in the economic assessment of backfitting an existing unit are:

1. The cost of installing the closed-cycle system, including materials, labor, site acquisition and preparation;
2. The plant downtime for hook-up and testing;
3. The provision of additional generating capacity to replace the lost capacity;

4. Operation and maintenance costs of the cooling system;
5. Operation and maintenance costs of replacement capacity;
and
6. Additional cost of power generation due to decrease in plant efficiency or limitations occasioned by the use of the closed-cycle system.

It will be clear that the first three of these are capital costs incurred at the time of backfitting while the last three are costs recurring over the remaining period of plant life. When these factors have been determined and the cost of borrowing the required capital expenditure are known, it is a simple matter to find the total cost, in mills per kilowatt-hour, to be charged against the actual power delivered after the backfit operation. The work described herein is concerned primarily with the evaluation of the various factors listed above. It is of course possible to design a closed-cycle cooling system regardless of whether it is a cooling tower, pond, or spray canal, which is sufficiently large to reproduce, very nearly, the performance of the once-through system being used at present. Such a system will obviously be expensive, at least from a first-cost point of view, and the various factors enumerated above will undoubtedly intervene and dictate a somewhat smaller closed-cycle system, requiring less operating and maintenance expenses. If the cost of backfitting is to be assessed in a realistic manner, it is then obvious that a range of sizes must be considered.